FIRE PREVENTION DIVISION

TRASH ENCLOSURE REQUIREMENTS

Automatic fire sprinklers shall be installed for all new trash enclosures.

Exceptions:

- Trash enclosures that are of non-combustible construction, including the roof or cover, and at least ten feet from any adjacent structure, and at least five feet from the nearest property line.
- Trash enclosures with non-combustible construction within ten feet of a building may be protected with sidewall sprinklers on the exposed building with the Fire Department's approval.