

Public Works Department
305 West Third Street, East Wing, Third Floor
Oxnard, California 93030
Tel 805.385.8280



November 17, 2021

ADDENDUM NO. 2

**EAST PARK & VINEYARD PARK PLAYGROUND RESURFACING
SPECIFICATION NO. SD 22-18**

BID DUE DATE: 2:00 P.M. TUESDAY, NOVEMBER 30, 2021

TO ALL BIDDERS OF RECORD:

Acknowledge receipt of this Addendum by enclosing one signed copy with your bid documents. Failure to do so may subject the bidder to disqualification. This Addendum consists of two (2) pages and forms a part of the bid documents as follows:

1. **RFI's.** The City has received the following requests for information regarding this project:

Question A:

Please clarify who is responsible for tree root removal, backfill and substrate preparation on the project.

Response A:

01. The City will be responsible for the removal of the tree roots in the work area after the Contractor has removed the playground surface.
02. The Contractor will be required to backfill with matching substrate or a homogeneous mix of $\frac{3}{4}$ " stone down to fines. Substrate will not exceed 10" in thickness in any location. If fill material is needed to achieve a less than 10" thick substrate layer, native soil shall be added to areas in need of backfilling prior to the addition of substrate.
03. The area to be backfilled shall be scarified prior to the addition of backfill and shall be compacted to 95% relative compaction.

04. The Contractor will be required to add substrate material as needed to level the surface area at both project locations. This Work is considered part of Special Provisions / 1002-3 "prepare subgrade" and is paid under Special Provisions / 1002-4. No additional payment will be made for backfill materials.

Addendum No. 2 Received:

Date: _____

Contractor's Name

Address

Authorized Signature

City State Zip Code

Name and Title

Telephone Number, Including Area Code