

Public Works Department
305 West Third Street, East Wing, Third Floor
Oxnard, California 93030
Tel 805.385.8280



June 21, 2022

ADDENDUM NO. 2
LIFT STATIONS 1, 2 AND 30 IMPROVEMENTS PROJECT
Specification No. PW 21-89

MANDATORY PRE-BID MEETING AND SITE VISIT: 9:00 a.m. on June 22, 2022
BID DUE DATE: 2:00 pm on August 2, 2022

TO ALL BIDDERS:

Acknowledge receipt of this Addendum by enclosing one signed copy with your bid documents. Failure to do so may subject the bidder to disqualification. This Addendum forms a part of the Contract Documents as follows:

1. The City received the following Request for Information regarding this Project:

QUESTION 1: Per Spec 055200 para. 3.03 (C), Stainless Steel Welding requirement is TIG. However, our facility / welder certs are based on FCAW / MIG for Stainless Steel Welding. Is it acceptable to use FCAW / MIG welding for Stainless Steel Materials?

RESPONSE 1: FCAW / MIG welding is acceptable for Stainless Steel Materials.

Addendum No. 2 Received:

Date: _____

Contractor's Name

Address

Authorized Signature

City State Zip Code

Name and Title

Telephone Number, Including Area Code