

**Public Works Department**  
305 West Third Street, East Wing, Third Floor  
Oxnard, California 93030  
Tel 805.385.8280



January 11, 2023

**ADDENDUM NO. 1**

**WILSON SENIOR CENTER ROOF REPLACEMENT PROJECT**  
Specification No. PW 23-33

**BID DUE DATE: 2:00 pm on January 25, 2023**

TO ALL BIDDERS:

Acknowledge receipt of this Addendum by enclosing one signed copy with your bid documents. Failure to do so may subject the bidder to disqualification. This Addendum forms a part of the Contract Documents as follows:

**A. The City received the following Request for Information regarding this Project:**

**Question 1:** The specs call for walk pads, normally it's just on the service side of the HVAC, but there were no details. Will the walk pads need to be around ALL duct work?

**Response 1:** Bidders are instructed to provide bid pricing for walk pad installation from access points to service sides of all HVAC (mechanical) equipment. Walk pads are not required to be installed around duct work.

**Question 2:** For the walls, there was a lot of detail, but we did not find the dimensions. Can you let us know the height and thickness of the walls?

**Response 2:** Wall height and thickness may vary from building to building. Bidders are advised to attend the Optional Pre-Bid Meeting and Site Visit at 10:00 a.m. on Thursday January 12, 2023 to verify height and thickness of walls.

**Addendum No. 1 Received:**

Date: \_\_\_\_\_

\_\_\_\_\_  
Contractor's Name

\_\_\_\_\_  
Address

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
City State Zip Code

\_\_\_\_\_  
Name and Title

\_\_\_\_\_  
Telephone Number, Including Area Code